



LILABA

ANALYTICAL LABORATORIES

A COMPLETE FOOD & WATER TESTING LABORATORY



LAL/QF/7.8/01

Report No. LAL-WT-290623255

TEST REPORT

ULR : TC717923000013952F

Page No. 1/2

Issued To:	Sample Code
Unnati International School	WT-290623255
Shanti Nagar 2 Behind Jain Terapanth Bhavan, Opposite Kim Arogya Kendra	Issue Date
Olpad-Nulad Road Kim Ta-Olpad, Dis-Surat Gujrat	02/06/2025
	Your ref.
	-

PART A: PARTICULARS OF SAMPLES

1. Date of Receipt	: 29/05/2025	19. Batch No./Lot No	: N.M
2. Analysis starting Date	: 30/05/2025	20. Date of Mfg.	: N.M.
3. Analysis completion Date	: 01/06/2025	21. Date of Expiry	: N.M
4. Sample Drawn By	: Customer	22. Brand Name, If Any	: N.M
5. Sampling Method	: N.A.	23. BIS Seal	: Not Applicable
6. Sampling Location	: N.A.	24. IO's Signature	: Not Applicable
7. Temp. at the time of Sampling	: N.A.		
8. Group Name	: Drinking Water. With Amendment No-4		
9. Sample Name	: Water		
10. Description of the Sample	: --		
11. Sample Condition	: Received in Good Condition		
12. Temp. at the time of Sample Receipt	: N.A.		
13. Test Report As Per	: IS 10500: 2012 With Amendment No-4		
14. Sample Qty. Received	: 1		
15. Any Other Information	: --		
16. Declared Value if any	: N.A.		
17. Grade/Nariety/Type/Class/Size/etc	: 1 Ur PET Bottle		
18. Mode Of Packing	: Individual packs		

PART B : TEST RESULTS

Water

Chemical Testing

Organoleptic And Physical Parameters (Clause 4, Table 1)

Sr. No.	TEST NAME	SPECIFIED REQUIREMENT	LOQ	RESULTS	TEST METHOD
1	pH Value	6.5-8.5 / No relaxation	-	7.15 at 25.2 degree celsius	IS 3025 (Part- 11)
2	Turbidity, NTU	Max. 1 / 5	0.10	0.2	IS 3025 (Part- 10)
3	Total dissolved solids, mg/l	Max. 500 / 2000	6.00	238.50	IS 3025 (Part- 16)

General Parameters Concerning Substances Undesirable In Excessive Amounts (Clause 4, Table 2)

Sr. No.	TEST NAME	SPECIFIED REQUIREMENT	LOQ	RESULTS	TEST METHOD
4	Chloride (as Cl), mg/l	Max. 250 / 1000	1.00	37.20	IS 3025 (Part- 32)
5	Fluoride (as F), mg/l	Max. 1.0 / 1.5	0.50	BLQ	IS 3025 (Part- 60)
6	Free residual chlorine, mg/l	Min. 0.2 / 1	0.10	BLQ	IS 3025 (Part- 26)

UNNATI INTERNATIONAL SCHOOL

Reviewed By

Mrs. Pooja Patel (Sr. Analyst
Chemical)**PRESIDENT / TRUSTEE**

Authorised Sign

Mr. Dilip Kukadiya (T.M. Chemical)

PRINCIPAL**UNNATI INTERNATIONAL SCHOOL**
KIM - NULAD9 Plot no. 88 to 92, Gate no. 3, Siddhivinayak Industrial Estate,
Opp. Opera palace, Laskana - Kholvad Road, Kholvad, Taluka-
Kamrej, Surat, Gujarat-394190, INDIA

Sales Inquiry +91 98243 22298 / +91 87587 19855

Admin Contact: +91 81549 92240 ♦ www.lilabalabs.com ♦ sales@lilabalabs.com ♦ admin@lilabalabs.com



LILABA

ANALYTICAL LABORATORIES

A COMPLETE FOOD & WATER TESTING LABORATORY



LAL/QF/7.8/01

Report No. LAL-WT-290623255

TEST REPORT

ULR: TC717923000013952F

Page No. 2/2

7	Nitrate (as NO_3), mg/l	Max. 45 / No Relaxation	1.00	6.56	IS 3025 (Part- 34)
8	Sulphate (as SO_4), mg/l	Max. 200 / 400	3.00	15.81	IS 3025 (Part- 24)
9	Total alkalinity as calcium carbonate, mg/l	Max. 200 / 600	5.00	157.85	IS 3025 (Part- 23)
10	Total hardness (as CaCO_3), mg/l	Max. 200 / 600	4.00	67.23	IS 3025 (Part-21)

REMARKS:

Nil

NOTE:

Please Refer Overleaf

END OF THE TEST REPORT


UNNATI INTERNATIONAL SCHOOL

PRESIDENT / TRUSTEE

PRINCIPAL
UNNATI INTERNATIONAL SCHOOL
KIM - MULAD

Reviewed By

Mrs. Pooja Patel (Sr. Analyst
Chemical)



Authorised Sign

Mr. Dilip Kukadiya (T.M. Chemical)